Certificate of Compliance

Certificate Number 280507 - E313095 E313095 - May 25, 2007 Report Reference Issue Date 2007 maggio 28



Issued to:

KAISER-MOTOREN GMBH

KIELER STRAßE 558 24536 NEUMUENSTER GERMANY

This is to certify that representative samples of

SYSTEMS, ELECTRICAL INSULATION

Class 155(F) Insulation System Designated Kaiser 155-1.0

Have been investigated by Underwriters Laboratories Inc.[®] (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate..

UL 1446 Systems of Insulating Materials - General, Sixth edition 2007-02-08; Standard(s) for Safety: CSA/CAN 22.2 No. 0-M91 Appendix B - Industrial Control Equipment

System Additional Information:

Insulation Designation Class Kaiser 155-1.0 155(F)

Maximum Hot Spot Temperature 155 hot spot

Outdoor (Enclosed)

Yes Yes

Indoor

The maximum working voltage, and Basic Impulse Level (BIL) if applicable, of this insulation system is 600 V.

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: 🔊, may be used in conjuction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceeding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada: 🔊 and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Roberta Zaffaroni Issued by:

Adele L. Milch Reviewed by: Adele L. Milch, Engineering Associate Leader

Roberta Zaffaroni, Engineering Team Leader

UL International Germany GmbH

UL International Germany GmbH Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.UL **International Germany GmbH**